www.testla.com.tr

TESTLA
Elektrik Laboratuvarları Tic. Ltd. Şti.

Kuzuluk Mah. Ankara Cad. No:34
Akyazı / SAKARYA / TÜRKİYE
+90 264 437 97 70
laboratuvar@testla.com.tr

Test
TS EN ISO/IEC 17025
AB-0386-T

AB-0386-T
2002.07.02/00
20.04.2020

TEST REPORT

Client Name/Address	**GMS PANO ELEKTRİK SAN. ve TİC. A.Ş.** Beylikdüzü O.S.B. Bakır ve Pirinç San. Sit. Leylak Cad. 1.Pafta 156. Ada 1. Parsel No: 4 Beylikdüzü / İSTANBUL		
Name and Identity of Test Item	GMS PANO Brand DT250 Wall Type LV Panel		
Order No.	**2002.07**	**Sample Acceptance Date**	**04.03.2020**
Num. Of Pages of The Report	33 + 18 pages of annexes 51 pages in total	**Test Date(s)**	**06.03.2020-17.04.2020**
Test Standard(s) Rating(s)	**IEC 61439-2:** 08.03.2012 **Clause**;10.2.2, 10.2.3.2, 10.2.3.2, 10.2.5, 10.2.6, 10.2.7, 10.3, 10.4, 10.5, 10.6, 10.7, 10.8, 10.9.2, 10.9.3, 10.10, 10.11, 10.13 Ui:400V, Uimp:4kV, Ue:400V, Main Busbar Ie:250A, Incoming Unit Ie:180A, Icw:36kA-1sec *Test clauses are given at the page 4.*		
Test Result(s)	**POSITIVE / Details are given on the following pages which are part of this report.**		

Remarks

TESTLA Elektrik Laboratuvarları accredited by TÜRKAK under registration number AB-0386-T for TS EN ISO/TS EN 17025:2012 as test laboratory.

Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Seal	Date	Person in Charge of Test	Approval Date
TESTLA ELEKTRİK LABORATUVARLARI TESTLAB · 2010 ·	**20.04.2020**	**Mehmet ŞUMNU**	**Caner EREN** **Laboratory Manager**

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature is not valid.