



www.testla.com.tr

TESTLA

Elektrik Laboratuvarları Tic. Ltd. Şti.

Kuzuluk Mah. Ankara Cad. No: 34
Akyazı / SAKARYA / TÜRKİYE
Tel: +90 264 437 97 70 Faks: +90 264 437 97 80



Test
TS EN ISO IEC 17025
AB-0386-T

AB-0386-T

1502.06.02


01/01

TEST REPORT

Client Name & Adress	GMS PANO ELEKTRİK SAN VE TİC. A.Ş. Beylikdüzü OSB.Bakır ve Pirinç San.Sit.Leylak Cad.no:4 BEYLİKDÜZÜ/İSTANBUL
Sample Description	DT4000 2500 kVA / 100 kA Type Test Panel and Empty (identical) Enclosure
Brand / Type / Serial Number	GMS PANO / 14.012.GMS.TEST
Demand-Accept No	1502.06.02
Sample Acceptance Date	10.03.2015
Test Date(s)	10.03.2015-25.03.2015
Num. Of Pages of The Report	28 + 20 pages of annexes 48 pages in total
Test Standard(s)	IEC 61439-1: 08.03.2012 Low-voltage switchgear and controlgear assemblies - Part 1: General rules IEC 61439-2: 08.03.2012 Low-voltage switchgear and controlgear assemblies - Part 2: Power switchgear and controlgear assemblies TS EN 62208: 08.03.2012 Empty enclosures for low-voltage switchgear and controlgear assemblies - General requirements Details are given on the following pages which are part of this report.
Remarks	The test results presented in this report relate only to the object tested. Tests marked (*) in this test report are not included in the TÜRKAK accreditation schedule for this laboratory.

The Turkish Accreditation Agency (TÜRKAK) is signatory to the multilateral agreements of the European co-operation for the Accreditation (EA) and of the International Laboratory Accreditation (ILAC) for the Mutual recognition of test reports.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Seal	Report Date	Person in Charge of Test	Laboratory Manager
	13.05.2015	 Mehmet SUMNU	 Caner EREN